


# Punjab Alkalies & Chemicals Limited

Regd. Office : S.C.O. 125-127, Sector 17-B, Chandigarh - 160 017 (INDIA)  
 Phone : 0172-4072508-568, E-mail : info@punjabalkalies.com Fax : 0172-2704797  
 CIN : L24119CH1975PLC003607, Website : www.punjabalkalies.com

RFQ Master Enquiry

Ref No PACL/ENQ/1/kgg/PL-RFQ-00864

Date 04/12/2018  
 Unit ALL



Dear Sir,

Kindly Send us your most competitive offers so as to reach us on or before 18-DEC-18 for the supply of the under mentioned items :

S. Item Code / No Description Of Material	Quantity Unit	
1 PL-039-1702C CL2 MOINTERING SYSTEM	2.000 NO	<p>For measuring and remote indication of Cl<sub>2</sub> gas in ambient air consisting of :</p> <p>(a) Sensor :            electrochemical type plug n play, hot swappable Cl<sub>2</sub> sensor having electronics measurement accuracy / uncertainty <math>\leq (+/-)</math> 0.02 PPM, loss of sensitivity per year <math>\leq (-)</math> 3%, expected service life=36 months, zero drift=less than 2% of full scale/month, non cumulative, span drift=less than 3% per month, enviromental conditions:            Temp(Min/max)=(-) 40 to (+) 65 Deg C, Humidity =13/95%,            combined accuracy, sensor response=vendor to mention.</p> <p>(b) Transmitter indicator :            Intrinsically safe transmitter should be a combined unit with sensor, range = 0 to 10 PPM or 0 to 5 PPM, O/p = 4 to 20 mA, analog isolated o/p for DCS, Tx. aux. power = 16 to 32VDC, 2 wire system with reverse polarity protection feature, Tx. enclosure = epoxy painted Al explosion proof certified by CCOE/CIMFR, local LCD display with push button UI fro programming, calibration, range setting, alarm setting etc. features, non intrusive calibration features, panel mounting accesories. Test and calibration certificate of authorized agency should be supplied along with Cl<sub>2</sub> detector.</p>

Terms & Conditions :

Note: Please send your offer in two separate envelopes having priced & technical bid before due date. Material is required at Nangal (punjab). Please Quote CST,VAT

For PUNJAB ALKALIES & CHEMICAL LIMITED

Please send your quotation in a sealed envelop mentioning our enquiry Ref.No. strictly on the top of the envelope.

KRISHAN KUMAR GOYAL

RFQ Master Enquiry

- 
- 1.Quotation received after the due date may not be considered.
  - 2.Exact rates of Sales Tax, Central Sales Tax, Excise duty,Octroi etc. whenever leviabile should be clearly specified by you in your quotation, as no subsequent claims will be entertained by us in respect of these, it will not be sufficient to applicable.
  - 3.Any alteration or erasure in the quotation should be absolutely legible & duly attested. Over-writing or over-typing of any information may disqualify your quotation.
  - 4.Our enquiry reference must be indicated clearly on top of the envelope.
  - 5.Your quotation must be for units specified in this enquiry and should be valid for 90 days from date of opening of offer.
  - 6.At our option we may change the quantity of our requirment, or delete items.
  - 7.Please give detailed specification and indicate the name of manufacturer of each item and enclose literature.
  - 8.Your offer should be duly supported by all relevent technical literature/catalogue/brochure etc.
  - 9.Please quote clearly whether your warehouse is covered under excise preview or not. We shall like you to supply material through cenvetable invoice. Next of modvat notes will be compared for commercial evaluation.

IMP: PLEASE INDICATE TARRIF/SUB HEAD UNDER WHICH EXCISE DUTY IS TO BE CHARGED.